

## **FOOTING LAYOUT AND PILE NOTES**

The details and notes shown on B10.1 are intended as a design and detailing aid. Only those details and notes required should be shown on the plans. Notes should be modified or added to match the requirements of each structure.

Steel shell piles in a bent that are exposed shall have a minimum wall thickness of 5/16" with a useable wall thickness of 1/4".

Unless otherwise noted, exposed pile bents shall be painted in accordance with specifications.

For estimating purposes, test piles shall be approximately 50 percent longer than normal piles.

**Revisions:**  
June 2006

Split Footing Layout & Pile Notes and Approved Points, Shoes, Boots, & Splicers into separate articles.