



IDAHO TRANSPORTATION DEPARTMENT

P.O. Box 7129
Boise ID 83707-1129

(208) 334-8000
itd.idaho.gov

POWELL EQUIPMENT STORAGE BUILDING

May 30, 2017
Requisition #: B000168

ADDENDUM #2

The following information consists of changes, additions, omissions, deletions, or clarifications to the above mentioned project. All other information will remain the same.

Contractor/Business Name: _____

NOTICE TO ALL BIDDERS

You are hereby notified of the following clarifications of and/or revisions to the Drawings and Specifications for the above referenced project.

THIS ADDENDUM is hereby made a part of the project requirements and contract documents for referenced project.

BE SURE to acknowledge it in your Bid Proposal form.

ITEM NO. 1

Drawing Sheet A2.1 General Structural Notes, Design Loads Clarification: The Flat-Roof snow load, PF of 35 PSF is incorrect. The correct Flat-Roof snow load is 112 PSF.

Attachments: none

There are no other changes.

End of Addendum Two

This page MUST BE SIGNED, DATED AND RETURNED with your BID DOCUMENTS

Signature: _____ Date: _____

I acknowledge receipt of this Addendum and its contents.