

1.3.4 REDUNDANCY

All Structures shall be designed to be Redundant. The η_R factor shall be 1.0 unless measures in addition to those already in the code are used. Two girder and three girder bridges shall be classified as not redundant and the η_R factor shall be 1.05.