

3.10.2 SEISMIC HAZARD

A site specific procedure shall be used if the site is within 6 miles of an active fault. The Geotechnical Engineer should be contacted to determine the response spectra. Site Specific Procedures are specified in Article 3.10.2.2.

Active fault locations for Idaho are shown on the following page.

Revisions:
April 2008

Revised article to agree with 2008 Interims.
Revised map to only show active fault locations.