



3311 State Street  
Boise, Idaho 83707  
Phone: 208-334-8000  
www.itd.idaho.gov

## **ADDENDUM NO. 1**

Date:	June 6, 2018	Owner:	ITD
Project:	Bliss Salt Storage Shed for ITD District 4		
Project No.:	18-401	No. of Pages	3

---

### **NOTICE TO ALL BIDDERS**

You are hereby notified of the following clarifications of and/or revisions to the Drawings and Specifications for the above referenced project.

**THIS ADDENDUM** is hereby made a part of the project requirements and contract documents for referenced project.

**BE SURE** to acknowledge it in your Bid Proposal form.

#### **ITEM NO.**

1. QUESTION: Will ITD pay for building permits?  
RESPONSE: ITD will pay for the building permit. Contractor is responsible for all other permits and associated costs.
1. QUESTION: Please clarify bid date and time.  
ANSWER: June 12, 2018 at 2:00 PM (MST)
2. QUESTION: Will alternate PFMB manufacturer be considered other than the approved?  
ANSWER: Prior to bid if they send a request prior to addendum deadline, after bid per the specifications
3. QUESTION: Who is responsible for the PFMB Design reactions and calculations?  
ANSWER: The General Contractors PEMB supplier per the specification sent to our office for review by the Structural Engineer.
4. QUESTION: Will testing be required for compaction of subgrade materials and concrete?  
ANSWER: Yes.
5. QUESTION: Who is required to pay for materials testing?  
ANSWER: General contractor is responsible to pay for materials testing per contract documents.
6. QUESTION: What constitutes a rubbed finish on concrete?  
ANSWER: See specification section

#### FINISHING FORMED SURFACES

- A. Rubbed Finish: Apply the following to smooth-formed finished as-cast concrete where indicated:
  1. Smooth-Rubbed Finish: **Not later than one day after form removal**, moisten concrete surfaces and rub with carborundum brick or another abrasive until producing a uniform color and texture. Do not apply cement grout other than that created by the rubbing process.

7. QUESTION: How should the bid envelope be addressed?  
RESPONSE: The bid envelope should be addressed to:

IDAHO TRANSPORTATION DEPARTMENT  
3311 STATE STREET  
BOISE, IDAHO 83707  
ATTENTION: TONY PIRC  
BID PROPOSAL: BLISS SALT STORAGE SHED FOR ITD DISTRICT 4

8. ATTACHMENTS:  
Pre Bid Sign In Sheet

**\*\*\*END OF ADDENDUM NO. 1\*\*\***

