



ADDENDUM 1

01/28/2025

To all bidders for the solicitation titled: **FM32524 –Heat Pump Assembly Room Replacement**

Please notify everyone concerned (subcontractors and suppliers) as to the issuance and contents of this Addendum prior to the date of bid opening. The following changes, deletions and/or additions have been made to the above mentioned solicitation. All other information will remain the same. This Addendum is a part of the contract documents and modifies them as follows:

1. QUESTION:

a. **ANSWER:**

2. CLARIFICATION:

- a. Modify the demolition plan to replace keyed note #5 in the assembly area room to be keyed note #4.
- b. Revise demolition keyed note #4 to read: DISCONNECT AND REMOVE HEAT PUMP THERMOSTAT. REMOVE EXISTING THERMOSTAT WIRE. MAINTAIN AND PROTECT EXISTING CONDUIT AND BACK BOXES.
- c. Revise new work keyed note #1 to read: INSTALL NEW THERMOSTAT IN THE SAME LOCATION AS THE ORIGINAL THERMOSTAT. PROVIDE AND INSTALL NEW CONDUCTORS FROM THE THERMOSTAT TO THE UNIT. UTILIZE THE EXISTING BACK BOX AND CONDUIT.

These questions and answers do not change the due date of this ITB.

This solicitation is due before: DATE AND TIME

Thank you.

Facility Management Contracting Officer
IDAHO TRANSPORTATION DEPARTMENT

I acknowledge that I have received and read this addendum, and that failure to return a signed copy of this addendum with my response may result in my bid being found non-responsive.

Bidder (company name): _____

Authorized Signature: _____

Printed Name: _____

Date: _____

THIS ADDENDUM MUST BE SIGNED, DATED AND RETURNED WITH YOUR RESPONSE

End of Addendum # 1