

Addendum # 1

**For the Bid of
Clarkia Salt Shed - 2023
FM12317
Highway 3
Clarkia, Idaho 83812
3/13/2022**

**From: Miller Stauffer Architects
601 E. Front Ave. Suite 201
Coeur d'Alene, ID 83814
Ph (208) 664-1773
Fax (208) 667-3174
Website: www.millerstauffer.com**

T.O. ALL PLAN HOLDERS

This Addendum consists of **02** pages to the Addenda.

Important: Bidders must acknowledge receipt of this addendum as well as all other issued addenda on the forms provided with the Contract Documents, which must be utilized by bidder for bid to be considered responsive. Failure to do so may subject bidder to disqualification.

1. General
 - a. Addition Alternate #3
 - i. Replace called out concrete floor with asphalt pavement to match exterior asphalt design, not included in the cost of Alternate 1 or 2. Base bid is to be concrete as shown in the drawings.
2. Drawings
 - a. Clarifications
 - i. Electrical E0.3 and E0.4 Specifications
 1. Raceways and boxes located in the salt storage and mag storage areas (corrosive environments) will be PVC SCHED 80.
 - ii. C 1.2 Civil Site Plan.
 1. Include bio-swale and drywell shown in civil sheets in Alternate 2 (driveway grading and associated paving).
 - b. Additions
 - i. None

- c. Deletions
 - i. None
 - d. Revisions
 - i. None
 - e. Substitutions
 - i. None
3. Specifications
- a. Clarifications
 - i. Section 002113 Instructions to Bidders
 - 1. Building permit fees are to be included in the project bid cost, the contractor is responsible for picking up the building permits.
 - 2. Contractor responsible for providing special inspections, see structural drawings for special inspections required.
 - 3. All bids will be turned in at the Boise location as indicated, no exceptions will be accepted. 11331 W Chinden Blvd. Boise, ID 83714.
 - ii. Section 74113.19 Metal Roof Panels & 74619 Steel Siding
 - 1. Approved equal manufacturers would include Metal Sales, Taylor Metal Products, PAC-CLAD and Miramac.
 - 2. Soffit material and type is called out in this specification and is to be metal.
 - b. Additions
 - i. None
 - c. Deletions
 - i. None
 - d. Revisions
 - i. Section 000101 Title Page
 - 1. Address for Idaho Transportation Department is 11331 W Chinden Blvd, Boise, ID 83714
 - ii. Section 002113 Instructions to Bidders (2.10 Mailed Bids)
 - 1. Address for Couriers / Physical Address: 11331 W Chinden Blvd. Boise, ID 83714, Building 8 West Lobby Slot #1 (Yellow) "Facilities Sealed Bids".
 - e. Substitutions
 - i. None

End of Addendum #1