



ADDENDUM 1

05/09/2025

To all bidders for the solicitation titled: **FM32527 – Lowman Roof Replacement**

Please notify everyone concerned (subcontractors and suppliers) as to the issuance and contents of this Addendum prior to the date of bid opening. The following changes, deletions and/or additions have been made to the above mentioned solicitation. All other information will remain the same. This Addendum is a part of the contract documents and modifies them as follows:

1) CLARIFICATION:

- a. Existing roof insulation on the building is comprised of original sandwiched layer of fabric faced insulation between the roof panel and purlins, along with another fabric face standard Pre-Engineered Metal Building (PEMB) insulation system suspended between the purlins using metal strapping. Disregard note on demolition plan regarding rigid insulation. All existing roof insulation and strapping shall be removed in its entirety in preparation for new PEMB roof insulation system per the drawings and specifications.

These questions and answers do not change the due date of this ITB.

This solicitation is due before: 05/14/25 at 1:59:59 PM (MST)

Thank you.

Facility Management Contracting Officer
IDAHO TRANSPORTATION DEPARTMENT

I acknowledge that I have received and read this addendum, and that failure to return a signed copy of this addendum with my response may result in my bid being found non-responsive.

Bidder (company name): _____

Authorized Signature: _____

Printed Name: _____

Date: _____

THIS ADDENDUM MUST BE SIGNED, DATED AND RETURNED WITH YOUR RESPONSE

End of Addendum #1