

ADDENDUM NO. 01

HA Project No. 22031

Project Name: ITD Big Creek Shed Rebuild
Address: 3900 Smith Creek Rd.
City, State, Zip: Yellow Pine, ID 83677

Owner Name: Idaho Transportation Department
Address: P.O. Box 7129
City, State, Zip: Boise, ID 83707-1129



Architect: Hummel Architects
205 N. 10th Street, Suite 300
Boise, Idaho 83702

Date Issued: July 15, 2024

Addendum No. 01

Notice to Bidders:

You are notified of the following Changes, Deletions, Corrections, Additions, Revisions, and/or Modifications to the Drawings, Specifications/Project manual and instructions to Bidders Dated: July 15, 2024 for the above-mentioned project which is made a part thereof. You must acknowledge receipt of this Addendum in the appropriate space provided on the Bid Proposal Form.

The Items of this Addendum are as follows:

Approvals: none.

Clarifications:

Pre-Bid Requests for Information		
Number	Comment / Question	Response
1	The architectural drawings call out a 7"/12" roof slope. The structural calculations call out a 8"/12" roof slope. Which slope is correct?	Maintain 7"/12" roof slope noted on architectural drawings.
2	What is the metal panel thickness or gage?	PEMB manufacturer to specify metal panel thickness to meet structural requirements.
3	Please provide pictures of existing site.	Existing site pictures attached.
4	On the structural calcs, the wall panels are PBR, they are called out at a 3lb per square foot loading; PBR panel only has a 1 lb per square foot loading.	3 PSF metal panel weight is provided to accommodate multiple manufacturer's products.
5	Since the building is uninsulated, do you want a vapor barrier at the roof section to keep it from sweating and raining down on the interior?	No vapor barrier required at roof.

ADDENDUM NO. 01

6	In the engineering there is a thermal factor of 1.2 listed. I am assuming that since there is no heat this is not an issue.	Maintain thermal requirements as noted in documents.
7	What colors are being requested on this building?	Provide finish selection from manufacturer's standard colors for metal roof panels and metal wall panels. Match trims and flashing to corresponding finish.

Project Manual: none.

Drawings: none.

Attachments:

-Existing site photos.

End of Addendum No. 01



Photo 1



Photo 2



Photo 3



Photo 4



Photo 5