



- NOTES:
1. THE FOUNDATION SHALL BE LOCATED AS INDICATED ON THE PLAN SHEETS.
 2. ALL CONDUITS, ELBOWS AND COUPLINGS WITHIN AND PROTRUDING FROM THE FOUNDATION SHALL BE RIGID STEEL. THE REMAINING CONDUITS SHALL BE AS SHOWN ON THE PLANS.
 3. STUBOUTS SHALL BE TERMINATED WITH A STEEL BONDING BUSHING.
 4. PLASTIC PUSH PLUG REQUIRED AT BOTH ENDS OF SPARE CONDUITS.
 5. GROUND IN ACCORDANCE WITH THE N.E.C.
 6. CONDUIT SHALL BE INSTALLED IN SUCH A MANNER AS TO NOT CAUSE MODIFICATION OF THE CABINET.
 7. GRADE TO PROVIDE DRAINAGE AWAY FROM THE CABINET FOUNDATION.
 8. 6" WIDE ELECTRICAL HAZARD TAPE SHALL BE INSTALLED 1'-0" ABOVE THE CONDUIT. (TYPICAL OF ALL CONDUIT PLACED IN GROUND).
 9. FOUNDATION REBAR CAGES MAY BE WELDED IF THE REBAR CONFORMS TO ASTM A706/A706M AND WELDING CONFORMS TO ANSI/AWS D1.4. (STRUCTURAL WELLING CODE - REINFORCING STEEL).
 10. USE SERVICE PEDESTAL BASE FOR ANCHOR BASE TEMPLATE.

ELECTRONIC CABINET AND SERVICE PEDESTAL FOUNDATION SCHEDULE													
CABINET TYPE	FOUNDATION TYPE	HOOPS			VERTICAL REBAR			CU. YDS. CONC. FOUNDATION	PAD	CABINET ANCHOR BOLTS QNTY.	SERVICE PEDESTAL ANCHOR BOLTS		
		NO.	SIZE	LIN. FT.	NO.	SIZE	LIN. FT.				QNTY.	SIZE	QNTY.
ELECTRONIC	170/334	4	4 x 2	86'-2"	9	*4	27'-8"	1.74	.35	4	1/2" X 12" X 3"	4	5/8" X 6" X 2"

REVISIONS				DESIGNED	SCALES SHOWN ARE FOR 11" X 17" PRINTS ONLY CADD FILE NAME: td08_0214.dgn DRAWING DATE: FEBRUARY, 2014	IDAHO TRANSPORTATION DEPARTMENT 	PROJECT NO.	td-08	English COUNTY KEY NUMBER SHEET OF	NOT APPROVED PRELIMINARY FOR CONSTRUCTION
NO.	DATE	BY	DESCRIPTION	DESIGN CHECKED			ELECTRONIC CABINET & SERVICE PEDESTAL FOUNDATION DETAIL FOR ITS AND PORTS OF ENTRY			
				DETAILED						
				DRAWING CHECKED						