



IDAHO TRANSPORTATION DEPARTMENT

P.O. Box 7129
Boise ID 83707-1129

(208) 334-8000
itd.idaho.gov

ATHOL MAINTENANCE BUILDING

April 30, 2018
Requisition #: 18-102/A405070

ADDENDUM #4

The following information consists of changes, additions, omissions, deletions, or clarifications to the above mentioned project. All other information will remain the same.

Contractor/Business Name: _____

Clarification 1

Plumbing Clarification:

FD2's along with P11's are showing on the four drains in the shop area. They should be P11's only.

The HB2's on the plumbing fixture schedule should be Woodford model 24P instead of the B65 as are shown.

Informational 1

Wayne Dalton Door is an approved overhead door.

There are no other changes.

End of Addendum Four

This page MUST BE SIGNED, DATED AND RETURNED with your BID DOCUMENTS

Signature: _____ Date: _____

I acknowledge receipt of this Addendum and its contents.