



3311 State Street  
Boise, Idaho 83707  
Phone: 208-334-8000  
www.itd.idaho.gov

## **ADDENDUM NO. 1**

Date:	June 6, 2018	Owner:	ITD
Project:	Shoshone Brine Making Facility		
Project No.:	18-406	No. of Pages	6

---

### **NOTICE TO ALL BIDDERS**

You are hereby notified of the following clarifications of and/or revisions to the Drawings and Specifications for the above referenced project.

**THIS ADDENDUM** is hereby made a part of the project requirements and contract documents for referenced project. **BE SURE** to acknowledge it in your Bid Proposal form.

### **ITEM NO.**

1. QUESTION: Will ITD pay for building permits?  
RESPONSE: Yes, ITD will pay for building permits. Contractor is responsible for trade permits.
2. QUESTION: How should the bid envelope be addressed?  
RESPONSE: The bid envelope should be addressed to:

IDAHO TRANSPORTATION DEPARTMENT 3311 STATE STREET  
BOISE, IDAHO 83707  
ATTENTION: TONY PIRC  
BID PROPOSAL: SHOSHONE BRINE MAKING FACILITY

3. ATTACHMENTS:  
Addendum #1, dated June 6, 2018, JHS Architects

**\*\*\*END OF ADDENDUM NO. 1\*\*\***



June 6, 2018

ADDENDUM NO. ONE (1)

PROJECT: ITD # 18-406  
Idaho Transportation Department  
Brine Making Facility  
Shoshone, Idaho

To: **All Bidders**

This addendum forms a part of the contract documents and modifies the original bidding documents as noted below. Except as affected by data included herein, all other parts of the contract documents shall remain in full force and effect. It shall be the sole responsibility of the bidder to appropriately disseminate this data to all concerned prior to the bid time and date. Acknowledge receipt of this addendum in the space provided on the bid form. Failure to do so may subject the bidder to disqualification.

This addendum consists of  2  pages and  3  page(s) attachment for a total of  5  pages.

**GENERAL ITEMS:**

- Item G1 Petra is the CM for this project up through Bidding and Contract Negotiations only. Petra will not be involved in the performance of Work by the General Contractor.
- Item G2 Contractor shall pay for any local trade permits as required.
- Item G3 Contractor shall utilize the Revised Bid Proposal form attached.
- Item G4 The attached Bid Proposal form includes Alternate No. 1 for all skylights shown on the drawings. Base Bid Proposal does not include skylights.

- Item G5        The attached Bid Proposal form includes Unit Cost for removal of basal rock. Contractor shall include a unit cost for removal of one cubic yard of rock. Unit Cost will be applied to the calculated area of rock differential between the rock exposed by excavation and the bottom of required excavations.
- Item G6        Excess excavation materials unsuitable for backfill shall be stock piled on site. Coordinate location with ITD.
- Item G7        Pre-Bid Conference meeting attendance is attached.

**ARCHITECTURAL ITEMS:**

- Item A1        Building finish floor elevation shall be 8” above highest existing grade elevation before any excavations. New exterior finish grade shall slope at 2% away from building and containment yard out to a point 10-ft from structure.
- Item A2        Structural fill and base material is not available on site and shall be any material ¾” minus that is compactable to 90%.
- Item A3        At Sectional Doors Specification 08 3613-3, 2.02 C.1, Delete subsections a, b, c, and d indicating buildings that are not part of this project. All overhead doors shown on drawings are to be Standard Lift Track.

**PLUMBING ITEMS:**

- Item P1        Plumbing Contractor to provide and install the following eyewash:  
Acorn Model S 0440-BF. Wall mounted eye/face wash, barrier free, ½” NPT chrome plated brass stay open ball valve w/stainless steel handle and in-line strainer, chrome plated brass, 1 ¼” tailpiece, stainless steel 11-3/4” diameter bowl, steel wall brackets w/yellow powder coated finish ANSI universal compliant sign and water proof test card. Run ½” cold water line to eyewash. Mount the unit at 36” off the finished floor level to the bottom of eye nozzles. Locate eyewash at north end of boiler equipment on east wall. Indirect waste to floor sink w/airgap. Field verify exact location with engineer and architect.

**END OF ADDENDUM NO. 1**

**BID PROPOSAL**

TO:

Gentlemen:

The Bidder, in compliance with your invitation for bids for the construction of the Idaho Transportation Department – Shoshone Brine Facility having examined the specifications with related documents and the site of the proposed work, and being familiar with all of the conditions surrounding the construction of the proposed project including the availability of materials and labor, hereby proposes to furnish all labor, materials and supplies, and to provide the service and insurance in accordance with the Contract Documents, within the time set forth therein, and at the prices stated below. These prices are to cover all expenses incurred in performing the work required under the Contract Documents, of which this proposal is a part.

Bidder hereby agrees to commence work under this contract on or before a date to be specified in written "Notice to Proceed" of the Owner and to substantially complete the project within 120 consecutive calendar days thereafter, as stipulated in the specifications. Bidder further agrees to pay as liquidated damages, the sum of \$100 for each consecutive calendar day thereafter as hereinafter provided in Paragraph 9.11.1 of the Supplementary Conditions.

Bidder acknowledges receipt of addenda No. \_\_\_\_\_.

**BASE PROPOSAL:** Bidder agrees to perform all of the base proposal work described in the specifications and shown on the plans for the sum of

\_\_\_\_\_ Dollars (\$\_\_\_\_\_).  
(Amount shall be shown in both words and figures. In case of discrepancy, the amount shown in words will govern.)

**ALTERNATE PROPOSALS:** Alternate No. 1 – Skylights

\_\_\_\_\_ Dollars (\$\_\_\_\_\_).  
(Amount shall be shown in both words and figures. In case of discrepancy, the amount shown in words will govern.)

**UNIT COST:** Basalt Rock Removal

One Cubic Yard Unit Cost of: \_\_\_\_\_ Dollars (\$\_\_\_\_\_).

Bidder understands that the Owner reserves the right to reject any or all bids and to waive any informalities in the bidding.

The bidder agrees that this bid shall be good and may not be withdrawn for a period of 60 calendar days after the scheduled closing time for receiving bids.

Upon receipt of written notice of the acceptance of this bid, Bidder will execute the formal contract attached within 10 days and deliver a Surety Bond or Bonds as required by Article 7 of the Instructions to Bidders including paragraph 7.1.1.1 of the Supplementary Instructions to Bidders.

The bid security attached in the amount of 5% of the bid amount is to become the property of the Owner in the event the contract and bond are not executed within the time set forth, as liquidated damages for the delay and additional expense to the Owner caused thereby.

Pursuant to Section 67-2310, Idaho Code, commonly known as the naming law, the names and addresses of the entities who will perform the plumbing, heating and air conditioning and electrical work, subject to approval of Owner and Architect, if Undersigned is awarded the Contract, are as follows:

**Plumbing** (Name)\_\_\_\_\_

(Address)\_\_\_\_\_

Idaho Public Works Contractors License No. \_\_\_\_\_

Idaho Plumbing Contractors License No. \_\_\_\_\_

**Heating/Air Conditioning** (Name)\_\_\_\_\_

(Address)\_\_\_\_\_

Idaho Public Works Contractors License No. \_\_\_\_\_

**Electrical** (Name)\_\_\_\_\_

(Address)\_\_\_\_\_

Idaho Public Works Contractors License No. \_\_\_\_\_

Idaho Electrical Contractors License No. \_\_\_\_\_

The Undersigned notifies that he is of this date duly licensed as a Contractor and further that he possesses Idaho Public Works Contractor's License No. \_\_\_\_\_.

Dated at \_\_\_\_\_ this \_\_\_\_\_ day of \_\_\_\_\_ 2018.

Respectfully submitted,

By: \_\_\_\_\_

(Company)

\_\_\_\_\_  
(Business Address)

\_\_\_\_\_  
(Authorized Signature)

\_\_\_\_\_  
(Title)

\_\_\_\_\_  
(Telephone Number)

(Seal - if bid is by a corporation)

END OF BID PROPOSAL

